

GLASGOW FIRE DEPARTMENT  
Standard Operating Guideline

<b>GUIDELINE: HOSE LAY PROCEDURES</b>			<b>SECTION: 211</b>
WRITTEN 08/13/90	REVIEWED	REVISED 10/22/08	Page 95

**INTENT**

The intent or purpose of hose lay procedures is to insure that personnel use the hose lays that provide prompt, adequate attack lines and water supply lines.

**REFERENCE**

1. Personnel shall use hose lays as per Section 135 Training Procedures Minimum Standards.
2. Officers or senior members shall use the hose lays that provide the most effective and efficient attack to suppress the incident.
3. Maximum operating pressure of Relay-supply hose is 185 P.S.I. This would include 3 1/2" to 5" hose that is used for relay supply.